

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-2013:0100 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Models AR-3 repeater, RB-10, RB-20, RB-30, RB-40 Relay Box, Model 330, 330-TS, 340, 340-TS Fire Transmitter, *Model YA-1 Yagi Antenna, and TR-3 End-of-Line Resistor. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for used with listee's separately listed Model CP-3000 fire alarm control unit. (Listing No. 7165-2013:0101)

*Rev. 09-08-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-2013:0101 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Model CP-3000 and *CP-3000D fire alarm control unit. Unit is suitable for automatic, manual, waterflow and sprinkler supervisory service, non-coded; local, auxiliary remote station (PPU), and and central station (PPU) when used with appropriate option modules and additional separate listed equipment. Unit may employ Model YA-1 Yagi Antenna.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.
*This control unit meets the requirements of UL-864, 9th Edition Standard.

*Rev 01-12-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-2013:0102 Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Models 300 and 301 photoelectric type, battery operated detectors with integral RF transmitter and audible signal. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3 VDC, Duracell DL123/ULTRA123 battery

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors when used in conjunction with listee's separately listed compatible Model CP-3000 fire alarm control unit (CSFM Listing No. 7165--2013:0101).

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires that consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

12-03-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-2013:0103 Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Model 302 Photoelectric Smoke Detector with no audible horn. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3 VDC, Duracell DL123/ULTRA123 battery or Panasonic CR123A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors when used in conjunction with listee's separately listed compatible Model CP-3000 fire alarm control unit (CSFM Listing No. 7165--2013:0101).

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires that consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

04-14-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7150-2013:0104

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Model 310 dual action manual pull box. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm manual pull box for use with separately listed compatible control units. For indoor use only. This manual pull box meets the requirements of UL Standard 38, 1999 Edition and California amendments.

06-08-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5276-2013:0105 Page 1 of 1

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Model 350 Single station, wireless RF carbon monoxide detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 3 VDC Battery replacement with Panasonic CR123A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as single station Carbon Monoxide detector with RF transmitter for residential applications. For use with listee's control panel Model CP-3000 or CP-3000D (CSFM listing number 7167-2013:0101). Refer to manufacturer's installation manual for details.

09-25-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7165-2013:0106

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Models CP-3000A and CP-3000DA fire alarm control unit. Unit is suitable for automatic, manual, waterflow and sprinkler supervisory service, non-coded; local, auxiliary remote station (PPU), and and central station (PPU) when used with appropriate option modules and additional separate listed equipment. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

09--09-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-2013:0107 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Model AR-3A Repeater and Model 340TS Wireless Fire Transmitter. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Model AR-3A - 120VAC
Model 340TS - 3VDC battery

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for used with listee's separately listed Model CP-3000 fire alarm control units. (Listing No. 7165-2013:0101 and 7165-2013:0106). Refer to manufacturer's installation manual for details.

09-09-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-2013:0108 Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 10798 N.W. 53rd Street, Sunrise, FL 33351
Contact: Scott Barrett (954) 318-6005 Fax (954) 318-6004
Email: scott@cwsifire.com

DESIGN: Models WRA-3, WRA-3R, WRA-3LG wireless remote annunciators . The suffix (R) and (LG) refers to color of the enclosure. R = Red, LG = Light Grey. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 V, 60 Hz, 0.5 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a wireless remote annunciator for used with listee's separately listed Models CP-3000A and CP-3000DA fire alarm control units (CSFM No. 7165-2013:0106). For indoor use only. Refer to manufacturer's installation manual for details.

01-06-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN**, Program Coordinator
Fire Engineering Division