

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-2013:0111 Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 6600 Congress Avenue, Boca Raton, FL 33487
Contact: Robert Feltham (561) 912-6754 Fax (954) 318-6004
Email: robertfeltham@tyco.com

DESIGN: Model 320 electronic/fixed temperature and rate-of-rise heat detector with an integral RF transmitter. The device is a 135°F fixed temperature and 15°F/Min. rate-of-rise detector. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 4.5 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and heat rating and UL label.

APPROVAL: Listed as a heat detector for use with listee's separately listed Model CP3500D fire alarm control panel (CSFM No. 7165-2013:0109). Refer to manufacturer's Installation Manual for details.

04-23-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division