

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-2013:0109 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 6600 Congress Avenue, Boca Raton, FL 33487
Contact: Robert Feltham (561) 912-6754 Fax (954) 318-6004
Email: robertfeltham@tyco.com

DESIGN: Model CP3500D fire alarm control unit. Unit is suitable for automatic, manual, waterflow and sprinkler supervisory service, non-coded; local, auxiliary remote station (PPU), and and central station (PPU) when used with appropriate option modules and additional separate listed equipment. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

12-12-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division