

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5276-2013:0105 Page 1 of 1

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: COMMERCIAL WIRELESS SYSTEM INTERNATIONAL 6600 Congress Avenue, Boca Raton, FL 33487
Contact: Robert Feltham (561) 912-6754 Fax (954) 318-6004
Email: robertfeltham@tyco.com

DESIGN: Model 350 Single station, wireless RF carbon monoxide detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 3 VDC Battery replacement with Panasonic CR123A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as single station Carbon Monoxide detector with RF transmitter for residential applications. For use with listee's control panel Model CP-3000 or CP-3000D (CSFM listing number 7167-2013:0101). Refer to manufacturer's installation manual for details.

09-25-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division